

Inspection Report

Permit Holder: Coastal GasLink Pipeline Ltd.

Inspection: 2025-4940

Inspection Date: 2025-12-09

Inspection Outcome: Inspected

Inspection Comment:

The inspector met with company representatives on site to review documentation and complete a site inspection tour.

The following documents/reports were reviewed:

- * Fire Detection and Suppression system inspections.
- * Combustible Gas fixed monitoring inspection.
- * Master Car Seal list and management process.
- * Critical Gas Regulator inspection.
- * Pressure Control and Overpressure protection device inspections.
- * Meter Calibrations.
- * Fugitive Emissions reports (LDAR).

Completed a Site Tour noting the following:

- * Good housekeeping practices were noted in buildings toured.
- * Gas/Fire detection displays showed no alarms or faults.
- * Car Seals were installed on critical devices inspected.
- * Regulators and PSV Pilots vented outside on devices inspected.

Thank you for the information provided and the time taken to complete the inspection.

A satisfactory Inspection was conducted.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100082211

Facility ID: 00018222

Facility Name: CGLPL WILDE LAKE 04-33-078-19 001

Facility Type: Compressor Station

Location: DLS: 04-33-078-19

Authorized by BCER



Inspection Number: 2025-4940
Inspection Date: 2025-12-09

Letter ID: L2507343
Letter Date: 2025-12-11