

Inspection Report

Permit Holder: Coastal GasLink Pipeline Ltd.
Inspection: 2026-0989
Inspection Date: 2026-03-18
Inspection Outcome: Inspected

Inspection Comment:

Met with permit holder representatives on site to complete a site inspection.

Reviewed the site Master Car Seal list and the Fire and Safety Equipment PM.

Completed a site inspection noting the following:

- * Car Seals installed on PSV and PT isolation valves
- * Regulators vented outside
- * Barricades in place protecting risers and installed equipment

Good housekeeping practices were noted in buildings inspected.

Thank you for taking the time review documents and complete the site inspection.

A satisfactory Inspection was conducted.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100084217
Facility ID: 00018343
Facility Name: CGLPL KITIMAT METER STATION A-077-A/103-I-02 001
Facility Type: Gas Sales Meter
Location: NTS: A- 077-A/103-I-02

Authorized by BCER