

Inspection Report

Permit Holder: AltaGas Ltd.
Inspection: 2026-1385
Inspection Date: 2026-04-30
Inspection Outcome: Inspected

Inspection Comment:

Met with Operation representative to review site documentation and complete a site inspection.

Reviewed the following documents:

- * Master Carseal list and carseal management process.
- * Fire and Gas fixed head detector calibrations.
- * Shutdown checks
- * Compressor Panel checks
- * ESDV and BDV function checks
- * ESD Push Button function checks
- * Flare ignitor inspection reports
- * Production Reporting meter calibrations
- * Tank inspection reports

Completed a site inspection noting the following:

- * ERP manual current and available
- * Fire/Gas panel displays showed no faults or alarms
- * Flare reporting process reviewed
- * Fuel Gas regulator vents routed outside
- * Carseals installed on ESDV bypasses and BDVs inspected

Please review flare stack area maintenance in preparation for upcoming 2026 fire season.

Good housekeeping practices were noted on site and in buildings inspected.

Thank you for taking the time to review site documents and complete a site inspection.

A satisfactory Inspection was conducted.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100048601
Facility ID: 00007442
Facility Name: ALTAGAS BLAIR D-058-F/094-B-16 003
Facility Type: Gas Processing Plant
Location: NTS: D- 058-F/094-B-16

Authorized by BCER