

Inspection Report

Permit Holder: NTE Energy Canada Ltd.
Inspection: 2026-1902
Inspection Date: 2026-06-05
Inspection Outcome: Inspected

Inspection Comment:

WA# 27229 - June 5, 2026: 11:25 hrs. on site.

Wellhead: SCV valve open, no LEL gas measured (Altair-5x), and no flow observed.

Kermit last reported gas production rate: 2026-04 (Active Status).

Signage is compliant to standards.

Well Facility: Cata-dyne regulator vent lines present. Service records inspected on site: meter calibration date: 2022 and orifice plate service date: 2024.

Storage: double wall tank on metal stand, grounded, and SDS labels present.

Flowline: flowline is connected to wellhead, well cabinet and pipeline.

NB: Wooden Matts stored on site.

A satisfactory Inspection was conducted.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100073611
Well ID: 27229
Well Name: NTE CANADA HZ GUNNELL B- 077-I/094-I-12
Location: NTS: B- 077-I/094-I-12

Permit: 100073611
Facility ID: 00025085
Facility Name: NTE CANADA GUNNELLCREEK B-077-I/094-I-12 001
Facility Type: Well Facility
Location: NTS: B- 077-I/094-I-12



Inspection Number: 2026-1902
Inspection Date: 2026-06-05

Letter ID: L2602680
Letter Date: 2026-06-08

Authorized by BCER