

Inspection Report

Permit Holder: Coastal GasLink Pipeline Ltd.

Inspection: 2026-2037

Inspection Date: 2026-05-21

Inspection Outcome: Inspected

Inspection Comment:

Met with Permit Holder representatives and completed a satisfactory Utility Gas prestart up inspection.

Discussed documents provided and discussed:

- * Master Carseal list
- * Purge and load procedure/drawings
- * Current Deficiencies list
- * Site ERP Plan

Completed a site tour of systems included in Utility Gas start up.

Documents provide by email after the inspection:

- * Signed Utility Gas PSSR
- * Meter Calibration reports
- * Pressure transmitter calibration reports
- * Utility Gas blind/lockout drawings

No concerns were noted at the time of the inspection.

Thank you for taking the time to provide the documentation and complete this inspection.

A satisfactory Inspection was conducted.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100115709

Facility ID: 00027591

Facility Name: CGLPL Mount Bracey D-099-G/093-J-16 001

Facility Type: Compressor Station

Location: NTS: D- 099-G/093-J-16



Inspection Number: 2026-2037
Inspection Date: 2026-05-21

Letter ID: L2602900
Letter Date: 2026-06-18

Authorized by BCER