

Inspection Report

Permit Holder: NTE Energy Canada Ltd.
Inspection: 2026-2109
Inspection Date: 2026-06-23
Inspection Outcome: Non-Compliance(s) Found

Inspection Comment:

WA# 20161 - June 23, 2026 - 11:15 hrs.

Wellhead: SCV valve open, no LEL gas measured (Altair-5x), and no flow observed.

Kermit last reported gas production rate: 2025-11 "Inactive Status"

Signage is compliant to standards.

Well Facilities: Cata-dyne regulator vent lines present. Service records inspected on site: Meter calibration record: 2022. MAXITROL gas line pressure regulator on cata-dyne heater system is missing its cap/seal.

Storage: single wall metal tanks (2x) in metal containment, drainage plug in place, grounded, and SDS label present.

Flowline: flowline is connected to wellhead, well building, and pipeline.

An Inspection was conducted and as a result Non-Compliance(s) were found and must be corrected. For specifics on the Non-Compliances, refer to the **Non-Compliance Notice**.

To respond to these Non-Compliances, access the CM-IS Permit Holder Application.

Consideration should be given to checking your other locations for similar Non-Compliances.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100050391
Well ID: 20161
Well Name: NTE CANADA ET AL HZ JUNIOR B- 078-B/094-I-11
Location: NTS: B- 078-B/094-I-11

Permit: 100050391
Facility ID: 00021587
Facility Name: NTE CANADA GUNNELLCREEK B-078-B/094-I-11 001
Facility Type: Well Facility
Location: NTS: B- 078-B/094-I-11



Inspection Number: 2026-2109
Inspection Date: 2026-06-23

Letter ID: L2603016
Letter Date: 2026-06-25

Authorized by BCER