

Inspection Report

Permit Holder: Canlin Energy Corporation
Inspection: 2026-2579
Inspection Date: 2026-07-22
Inspection Outcome: Inspected

Inspection Comment:

3167 - July 21, 2026: 15:05 hrs. on site

KERMIT last gas production date: 2026-05 (Active Status): wellhead is connected to flowline, and pipeline.

Signage posted requires an updated flammable safety symbol/decal at the well pad location or at the road entrance (presently flammable safety symbol/decal is faded and not readily legible).

Well Building: Cata-Dyne heater system vent lines are in place. Meter calibration record: 2026 and orifice plate service record: 2026.

Storage: double wall metal tank (1x) on a metal stand, SDS labels present, and grounded.

Flowline: flowline control valves handles are in the open position and connected from well through facility to pipeline - "Active Status".

A satisfactory Inspection was conducted.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100004288
Well ID: 03167
Well Name: CANLIN LAPRISE D- 055-I/094-G-08
Location: NTS: D- 055-I/094-G-08

Permit: 100004288
Facility ID: 00018640
Facility Name: CANLIN LAPRISECREEK D-055-I/094-G-08 001
Facility Type: Well Facility
Location: NTS: D- 055-I/094-G-08



Inspection Number: 2026-2579
Inspection Date: 2026-07-22

Letter ID: L2603660
Letter Date: 2026-07-22

Authorized by BCER