

Inspection Report

Permit Holder: Canadian Natural Resources Limited
Inspection: 2026-2718
Inspection Date: 2026-07-23
Inspection Outcome: Non-Compliance(s) Found

Inspection Comment:

WA# 15170 - July 23, 2026 on site.

Wellhead: SCVA ball valve handle was observed in the open position: no LEL gas was measured (Altair-5x), and no flow was observed.

Kermit last reported gas production rate: 2026-06 "Active Status".

Signage is compliant to standards.

Well Facility: Cata-Dyne regulator vent lines are present. Service dates: Meter calibration date: 2026 and orifice plate service record: 2026.

Storage: no storage tanks present or in use on site.

Flowline: flowline is connected to wellhead, and well building, and pipeline.

An Inspection was conducted and as a result Non-Compliance(s) were found and must be corrected. For specifics on the Non-Compliances, refer to the **Non-Compliance Notice**.

To respond to these Non-Compliances, access the CM-IS Permit Holder Application.

Consideration should be given to checking your other locations for similar Non-Compliances.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100035154
Well ID: 15170
Well Name: CNRL GUTAH C- 040-K/094-H-10
Location: NTS: C- 040-K/094-H-10

Permit: 100040948
Pipeline Project ID: 000012789
Segment IDs (Location): 1 (From NTS: C- 040-K/094-H-10 To NTS: A- 054-K/094-H-10)

Authorized by BCER



Inspection Number: 2026-2718
Inspection Date: 2026-07-23

Letter ID: L2603864
Letter Date: 2026-07-29