

Inspection Report

Permit Holder: Cavvy Production Ltd.
Inspection: 2026-2867
Inspection Date: 2026-08-05
Inspection Outcome: Inspected

Inspection Comment:

Wells are Active.

Signs compliant to DPR standard.

Surface casing vents open. LEL detected from c-A52-I, consistent with 2013 test data. No LEL detected from c-52-I.

Last meter cal/orifice plate check June 2026.

Building compliant, no leaks. All critical valves secured.

Pig barrel compliant to Pipeline Regulation.

2 Chem tank compliant; grounding, containment, WHMIS.

A satisfactory Inspection was conducted.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100040839
Well ID: 17144
Well Name: CAVVY ET AL HZ EKWAN C- 052-I/094-I-10
Location: NTS: C- 052-I/094-I-10

Permit: 100044134
Well ID: 18271
Well Name: CAVVY ET AL HZ EKWAN C-A052-I/094-I-10
Location: NTS: C-A052-I/094-I-10

Permit: 100040839
Facility ID: 00020520
Facility Name: CAVVY EKWAN C-052-I/094-I-10 001
Facility Type: Well Facility
Location: NTS: C- 052-I/094-I-10

Permit: 100044401

Pipeline Project ID: 000013670

Segment IDs (Location): 1 (From NTS: C- 052-I/094-I-10 To NTS: B- 035-I/094-I-10)

Authorized by BCER