

Inspection Report

Permit Holder: Canadian Natural Resources Limited

Inspection: 2026-2883

Inspection Date: 2026-08-11

Inspection Outcome: Inspected

Inspection Comment:

Met with permit holder representatives on site to review documents and complete a site inspection tour.

Documents provided for review:

- * Carseal/Lock list
- * Compressor Panel Checks
- * Facility Shutdown Checks
- * ESD button checks
- * ESDV function checks
- * Fixed Fire and Gas Calibrations
- * Flare ignitor inspection
- * Fugitive Emissions reports
- * Reporting meter calibrations

Completed a site walkdown noting the following:

- * ERP manual is current
- * Fire and Gas detector display screen showed no faults or alarms
- * Discussed Flare reporting process
- * PAV chains in place
- * Critical devices inspected were locked/carsealed

Good Housekeeping practices were noted on site and in buildings inspected.

Thank you for taking the time to review documentation and complete a joint site inspection.

A satisfactory Inspection was conducted.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100065615

Facility ID: 00008619

Facility Name: CNRL NARRAWAY A-065-A/093-I-09 003

Facility Type: Gas Processing Plant

Location: NTS: A- 065-A/093-I-09

Permit: 100065910
Facility ID: 00007672
Facility Name: CNRL OJAY A-065-A/093-I-09 004
Facility Type: Compressor Dehydrator
Location: NTS: A- 065-A/093-I-09

Authorized by BCER