

Inspection Report

Permit Holder: NTE Energy Canada Ltd.

Inspection: 2026-3323

Inspection Date: 2026-09-08

Inspection Outcome: Inspected

Inspection Comment:

WA# 19720 - Sept. 8, 2026: 12:31 hrs.

Wellhead: SCVA ball valve handle is in the open position, no LEL gas was measured (Altair-5x), and no flow was observed.

Kermit last reported gas production rate: 2026-07 "Active Status".

Signage is compliant to standards.

Well Facilities: Cata-dyne regulator vent lines present. Service records inspected on site: Meter calibration record: 2022 and orifice plate service record date: 2026.

Storage: single wall tanks (2x) in metal secondary containment, drain plug in place/installed, grounded, and SDS label present.

Flowline: flowline is connected to wellhead, well building, and pipeline.

A satisfactory Inspection was conducted.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100049015

Well ID: 19720

Well Name: NTE CANADA HZ DILLY A- 008-K/094-P-12

Location: NTS: A- 008-K/094-P-12

Permit: 100049015

Facility ID: 00021347

Facility Name: NTE CANADA PETITOTRIVER A-008-K/094-P-12 001

Facility Type: Well Facility

Location: NTS: A- 008-K/094-P-12

Permit: 100048924

Pipeline Project ID: 000015366

Segment IDs (Location): 1 (From NTS: A- 008-K/094-P-12 To NTS: A- 010-K/094-P-12)



Inspection Number: 2026-3323
Inspection Date: 2026-09-08

Letter ID: L2604718
Letter Date: 2026-09-17

Authorized by BCER