Inspection Report

Permit Holder: NTE Energy Canada Ltd.
Inspection: 2026-3677
Inspection Date: 2026-11-16
Inspection Outcome: Inspected

Inspection Comment:
Nov. 17, 2026: 14:53 hrs.

Pipeline Project # 000018435 Segment # 1

Riser Junction - Komie Rd. - C-46-A_94-P-04 (59.034824 / -121.575958)

All bull plugs are in place, no leaks or spills noted.

NB: Pig closure catchment basins (1x) covers are not latched secured and Pig barrel safety chain is not attached to PAV.

A satisfactory Inspection was conducted.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100055830
Pipeline Project ID: 000018435
Segment IDs (Location): 1 (From NTS: D- 047-A/094-P-04 To NTS: C- 046-A/094-P-04)

_____

Authorized by BCER