Inspection Report

Permit Holder: NTE Energy Canada Ltd.
Inspection: 2026-3845
Inspection Date: 2026-11-26
Inspection Outcome: Non-Compliance(s) Found

Inspection Comment:
WA# 19404 - Nov. 26, 2026: 10:51 hrs. on site.

Wellhead: SCVA ball valve handle is in the open position, SCVF are being reported/monitored to standards.

KERMIT last reported gas production: 2026-09

Signage is compliant to standards.

Facility: Cata-Dyne regulator vent lines present. Service records are posted on site: meter calibration: 2022 and orifice plate service record: 2026.

Storage: single wall tank (2x) in metal containment, drain plug installed/in place, grounded, and SDS labels present.

Flowline: flowline is connected to wellhead, well cabinet, and pipeline.

An Inspection was conducted and as a result Non-Compliance(s) were found and must be corrected. For specifics on the Non-Compliances, refer to the **Non-Compliance Notice**.

To respond to these Non-Compliances, access the CM-IS Permit Holder Application.

Consideration should be given to checking your other locations for similar Non-Compliances.

The following were the only items that were inspected during this Inspection and does not absolve the company of Non-Compliances which may not have been observed, nor any Non-Compliances which occur subsequent to this Inspection.

Permit: 100048078
Well ID: 19404
Well Name: NTE CANADA HZ GUNNELL D- 048-B/094-I-13
Location: NTS: D- 048-B/094-I-13

Permit: 100048078
Facility ID: 00021173
Facility Name: NTE CANADA GUNNELLCREEK D-048-B/094-I-13 001
Facility Type: Well Facility
Location: NTS: D- 048-B/094-I-13

Authorized by BCER