

Non-Compliance Notice - Issued

Permit Holder: NTE Energy Canada Ltd.
Discovery Date: 2026-06-02
As a result of Inspection 2026-1833

An Inspection was conducted and as a result the following Non-Compliances were found. These Non-Compliances must be corrected by the required Correction Due Dates as indicated below. Consideration should be given to checking your other locations for similar Non-Compliances. To respond to these Non-Compliances, access the CM-IS Permit Holder Application.

<p>Non-Compliance Number: 2026-0346-01</p> <p>Issued Date: '2026-06-04'</p> <p>Status: Issued</p> <p>Outcome:</p> <p>Correction Duration: 14 Days</p> <p>Correction Due Date: '2026-06-18'</p>	<p>Permit: 100039243 Facility ID: 00020388 Facility Name: NTE CANADA GUNNELLCREEK A-033-G/094-I-13 001 Facility Type: Well Facility Location: NTS: A- 033-G/094-I-13</p> <p>Legislation: Energy Resource Activities Act 37 (1) A permit holder and a person carrying out an energy resource activity must (a) prevent spillage, and</p>
<p>Non-Compliance Comment: Missing drain plug on chemical storage metal containment hosting single wall tanks (2x) partially filled (1/2) with product.</p>	

Authorized by BCER